




Certificate of Performance



This certificate is awarded to **Profine India Window Technology Pvt. Ltd.**
for the performance of **Alupure / Koemmerling APSL- 31mm Sliding System of size 2700 mm (W) x 2100 mm (H)**
tested at our laboratory on **7th July 2018** as per **BS EN 1026, BS EN 1027, and BS EN 12211.**
The classification of the tested sample is given below.

Air permeability test **CLASS 3** as per (BS EN 12207: 2000)
Water penetration test **CLASS 5A** as per (BS EN 12208: 2000)
Wind load resistance test as per **CLASS B5** as per (BS EN 12210: 2000)


GOH AIK WEE
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.


CHIN YUN FEN
Managing Director