




# Certificate of Performance



This certificate is awarded to Profine India Window Technology Pvt. Ltd.  
for the performance of Alupure / Koemmerling APC - 4Gmm casement system of size 700 mm (W) x 1500 mm (H)  
tested at our laboratory on 7th July 2018 as per BS EN 1026, BS EN 1027, and BS EN 12211.  
The classification of the tested sample is given below.

Air permeability test **CLASS 3** as per (BE EN 12207: 2000)  
Water penetration test **CLASS 7A** as per (BS EN 12208: 2000)  
Wind load resistance test as per **CLASS B5** as per (BS EN 12210: 2000)

  
**GOH AIK WEE**  
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.

  
**CHIN YUN FEN**  
Managing Director