



Certificate of Performance




This certificate is awarded to Profine India Window Technology Pvt. Ltd.
for the performance of Alupure / Koemmerling – Opulenz Sliding Door of size 4 m (W) x 4 m (H)
glass thickness SGU 15.52mm Thick Thick (8mm + 1.52mm + 6mm Laminated Glass)
tested at our laboratory on 4th March 2021 as per BS EN Standards.
The performance of the tested sample is given below.

AS PER BS EN STANDARD

Air permeability test **CLASS 4** as per (BS EN 12207: 2016)
Water penetration test **CLASS 7A** as per (BS EN 12208: 2000)
Wind load resistance test as per **CLASS BE₃₀₀₀** as per (BS EN 12210: 2016)

Detailed Performance Report No. : **WINWALL IND - W0244 / 20 - 21**


GOH AIK WEE
Director

WINWALL TECHNOLOGY INDIA PRIVATE LTD.


CHIN YUN FEN
Managing Director